

# Plumbing Pressure Test Memorandum

Issued by:  
(Plumber)

Nick Whelan

Registration  
Number:

22327

Company  
Name:

Advance Plumbing and Gas

Company  
Address:

17 Woodward Street  
Hamilton

Company  
Contact  
Details:

Ph:

0800 999 441

Mb:

Fx:

To:

- ☒ Hamilton City Council ☐ Hauraki District Council ☐ Matamata-Piako District Council ☐ Otorohanga District Council  
☐ Thames-Coromandel District Council ☐ Waikato District Council ☐ Waipa District Council ☐ Waitomo District Council

Building  
Consent  
Number:

2021. 00043914.001

Building  
Owner:

Martin Cameron

Project  
Address:

136 State Highway 26, Newstead

Description  
of Building  
Work:

Completion of a pressure test on the plumbing system

Scope of work  
covered by  
statement:

We certify that the system was tested to 1500kpa for a period of 30 minutes. This test was conducted in accordance with manufacturer recommendations and complies with the pressure testing provisions of the New Zealand Building Code and Approved Solution G12 AS1 and AS/NZS3500.1.2 as appropriate.

☒ I understand that this Statement, if accepted, may be relied upon for the purpose of establishing compliance with the Building Code and Building Consent.

Signed by:  
(Plumber)



Date:

9-8-23